

Description	N/A	✓	Notes
1. Firefighting access:			
a. to every unsprinklered above-grade storey within prescribed distance above grade by at least one unobstructed window or access panel of prescribed dimensions:			
i. for each section of prescribed wall length			
ii. on each wall required to face a street			
iii. window glazed with plain glass <i>or</i>			
iv. access panel readily openable from both inside and outside			
b. to unsprinklered basements having greater than prescribed horizontal dimension:			
i. refer to floor plans - basements			
2. Spatial separation/exposure protection of exterior walls			
a. determine permitted maximum area of unprotected openings in an exterior wall for applicable limiting distance:			
i. for unsprinklered/sprinklered buildings <i>as prescribed</i>			
ii. convert area of unprotected openings to % of wall area for inclusion in building code data summary			
b. bmaximum area of unprotected openings doubled if openings glazed with:			
i. fixed wired glass assemblies			
ii. glass block reinforced in each horizontal joint			
c. exceptions for walls of open-air storage garage having greater than prescribed minimum limiting distance			