

Description	N/A	✓	Notes
1. Firefighting access:			
a. to unsprinklered basements having greater than prescribed horizontal dimension:			
i. from at least one street			
ii. by doors/windows/other means, dimensions <i>as prescribed</i> , or			
iii. interior stairway immediately accessible from outdoors			
2. Fire separations/firewalls:			
a. openings protected with closures having prescribed fire protection rating:			
i. refer also to notes for floors above grade, below			
b. unsprinklered basements compartmentalized at prescribed maximum areas			
c. firewall at floor above not required to continue into basement storage garage below			
3. Fire stops in unsprinklered crawl spaces: compartmentalized at prescribed maximum areas/dimensions			
4. Storeys extending more than one storey below ground:			
a. sprinklered			
b. floor assemblies constructed as fire separations with fire-resistance rating <i>as prescribed</i>			
c. exceptions for residential occupancies <i>as prescribed</i>			
5. Underground walkways connecting buildings:			
a. non-combustible construction			
b. sprinklered			
c. separated from buildings by fire separations with fire-resistance rating <i>as prescribed</i>			
d. smoke barrier doors spaced along walkway <i>as prescribed</i>			
e. travel distance to nearest exit <i>as prescribed</i>			
6. Industrial occupancies:			
a. basements used as repair/storage garages:			
i. access to stairways/elevators through vestibules			
ii. continuous curb/guard of prescribed heights around every floor opening/perimeter where exterior walls omitted			
b. vapour-tight separation required to separate basements/building services rooms from remainder of building where volatile/explosive materials are stored/manufactured/handled			