		Description	N/A	\checkmark	Notes
1.	Fire	e separations:			
	a.	fire stop flaps in rated membrane ceiling assemblies			
	b.	delineate % of total ceiling areas for finishes which may exceed flame-spread rating/smoke developed classification as prescribed			
2.	Fire	e detection systems:			
	a.	fire detectors/smoke and heat detectors installed in all prescribed rooms			
	b.	fire and heat detectors not required in sprinklered floor areas			