

Description	N/A	✓	Notes
1. Doors and frames:			
a. minimum headroom clearance <i>as prescribed</i>			
b. maximum reduction of headroom by door closer/other device <i>as prescribed</i>			
c. doors in fire separations labeled:			
i. fire protection ratings <i>as prescribed</i>			
(1) 20-minute closure ratings permitted <i>as prescribed</i>			
2. Door hardware:			
a. latches <i>as prescribed</i> :			
i. roller catches permitted in care facilities <i>as prescribed</i>			
b. self-closing devices:			
i. door stops <i>as prescribed</i>			
3. Weatherstripping to retard passage of smoke <i>as prescribed</i>			
4. Exit doors:			
a. readily operable without keys/special devices:			
i. except in secure areas <i>as prescribed</i>			
b. no automatic locking except for doors into hotel rooms			
c. hardware mounted not higher than prescribed distance above floor			
d. closers/electromagnetic hold-open devices <i>as prescribed</i>			
e. electromagnetic locking devices permitted except for certain prescribed occupancies			
5. Wall/partition/roof types:			
a. note fire-resistance ratings when applicable:			
i. ULC references or equivalents			